



## Residential S/W Disconnect and Reinstatement Policy

### General:

- Call Public Works (952) 826-0375 to schedule inspection, M-F 7:00-3:00
- Do not backfill prior to inspection
- All inspections will be by City Staff. Photo/video from contractor in place of visual inspection will NOT be accepted unless pre-approval by City Staff
- Permit must be on job site

### Sewer:

- Disconnect shall be capped at ROW or as close as possible with pre-approval from City Staff if reinstatement is planned. If abandoning service, disconnect shall be at the wye connection to the main
- New building sewer pipe must meet standards set forth in Table 701.1 of the 2015 MN Plumbing Code
- Any existing/left in place pipe (except structurally sound DIP or CIP) MUST be lined (including portion from disconnect to main) and must be televised at the time of inspection
- Orangeburg must be removed
- Maximum bend of fitting, 22.5'

### Water:

- Disconnects shall be at Curb Stop (CS) if reinstatement is planned. If abandoning service, disconnect shall be at the main
- When reinstating service, new pipe shall be 1" K copper from main to CS. If using existing %" corp, 3/4" to 1" increaser is allowed. If corp is abandoned, must be closed and capped or pigtail folded over. New corp tap will be minimum 2' from abandoned corp. If main is HDPE or C900, tapping sleeve is required
- All new pipe (main to CS and CS to house) must be solid piece. No joints/fittings allowed.  
\*Exception, copper may be silver soldered if length of run requires more than one roll
- Pipe material from CS to house must meet standards set forth in Table 604.1 of the 2015 MN Plumbing Code. \*See Trace Wire/Grounding Requirements for nonconductive material. Line trace by City Staff is required at time of inspection. Conductivity tests will NOT be accepted